

SECTION 04085

MASONRY ANCHORS AND ACCESSORIES

PART 1 GENERAL

1.1 SECTION INCLUDES

\*\*\*\*\*  
NOTE: Delete items below not required for project.  
\*\*\*\*\*

- A. Masonry veneer anchors and ties.
- B. Stone veneer anchors and ties.
- C. Masonry accessories.

1.2 RELATED SECTIONS

- A. Section 04810 - Unit Masonry Assemblies.
- B. Section 04851 - Cut Stone Veneer.
- C. Section 04852 - Stone Masonry Veneer.

1.3 REFERENCES

\*\*\*\*\*  
NOTE: Delete references from the list below that are not actually required by the text of the edited section.  
\*\*\*\*\*

- A. ASCE/ACI 530-05 - Specifications for Masonry Structures; 2005.
- B. ASTM A 153/A 153M - Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 1998.
- C. ASTM A 167 - Standard Specification for Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip; 1996.
- D. ASTM A 240/A 240M - Standard Specification for Heat-Resisting Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels; 1998b.
- E. ASTM A 276 - Standard Specification for Stainless Steel Bars and Shapes; 1998b.
- F. ASTM A 479/A 479M - Standard Specification for Stainless and Heat-Resisting Steel Bars and Shapes for Use in Boilers and Other Pressure Vessels; 1997a.

- G. ASTM A 580/A 580M - Standard Specification for Stainless Steel Wire; 1998.
- H. ASTM A 653/A 653M - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 1998.
- I. ASTM B 633 - Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel; (Reapproved 1994).

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data on each type of product furnished.

PART 2 PRODUCTS

2.1 MANUFACTURERS

Acceptable Manufacturer: Heckmann Building Products Inc.,  
 1501 N. 31<sup>st</sup> Avenue, Melrose Park, IL 60160  
 800-621-4140 or 708-865-2403 FAX: 708-865-2640

Email: [info@heckmannanchors.com](mailto:info@heckmannanchors.com)  
 Website: [www.heckmannanchors.com](http://www.heckmannanchors.com).

\*\*\*\*\*  
 NOTE: Delete paragraph below; coordinate with Division 1 requirements.  
 \*\*\*\*\*

- A. Requests for substitutions will be considered in accordance with provisions of Section 01600.
- B. Substitutions: Not permitted.

2.2 APPLICATIONS

- A. Provide anchoring systems that comply with ACI 530.1/ASCE 6/TMS 602.

\*\*\*\*\*  
 NOTE: The following anchors are one part of a two-part system - the part that attaches to the backup or structure. These anchors are suitable for masonry veneer, stone, and other claddings. Be sure, if any of these are used, that the second part - the tie or other attachment to the cladding - is also specified.  
 \*\*\*\*\*

- B. Masonry Anchors:

1. Anchors to Masonry Backup: Channel slots screwed to face.

**131 MASONRY TYPE CHANNEL SLOT**

[16 gage][11 gage] x 1-3/8 inches (35 mm) wide x 8 inches (203 mm) long with welded Z-Anchors [Length (1/2 of block thickness)] and 1-1/2 inch (38 mm) bends

\*\*\*\*\*

Note: Select one of the following 3 combinations of materials: all stainless steel, all hot-dip galvanized, or hot-dip galvanized except for items completely embedded in mortar. Delete the inappropriate choices.

\*\*\*\*\*

- C. Material for Anchors and Ties in Exterior Walls: Stainless steel.
- D. Material for Anchors and Ties in Exterior Walls: Hot-dip galvanized.
- E. Material for Anchors and Ties Exposed to Air in Exterior Walls: Hot-dip galvanized.
- F. Material for Ties Completely Embedded in Mortar Joints: Mill galvanized.

2.3 MATERIALS

- A. Stainless Steel: Type 304.
  - 1. Sheet Metal: ASTM A 167 or ASTM A 240/A 240M.
  - 2. Bars: ASTM A 479/A 479M, annealed and ground.
- B. Hot-Dip Galvanized Steel: Hot-dip galvanized after fabrication in accordance with ASTM A 153/A 153M, Class B-2.
- C. Mill Galvanized Steel:
  - 1. Sheet Metal: ASTM A 653/A 653M, G60 coating.
  - 2. Wire: ASTM A 641, regular coating; minimum 3/16 inch (4.76 mm) diameter.

- 1. Type for building into masonry: **131 MASONRY TYPE CHANNEL SLOT** [16 gage][11 gage] x 1-3/8 inches (35 mm) wide x 8 inches (203 mm) long with welded Z-Anchors [Length (1/2 of block thickness)] and 1-1/2 inch (38 mm) bends

PART 3 EXECUTION

3.1 INSTALLATION

A. Install as specified in applicable masonry section(s) and in accordance with manufacturer's instructions.

A. **131 MASONRY TYPE CHANNEL SLOT:** Place Z-Anchors in the core of the CMU. Push the Channel Slot back until it is flush with the face of the CMU. Grout core.

1. Ties: Insert tie into channel and rotate 90 degrees.

END OF SECTION