#### # 1050 Termination Bar

# SECTION 04 00 00 MASONRY Section 04 05 23 Masonry Accessories Section 07 62 00 Sheet Metal Flashing and Trim

#### **PART 1: GENERAL**

### 1.1 RELATED SECTIONS

A. Provide shop drawings for all product locations.

# 1.2 SUBMITTALS

- A. Manufacturer Certificate of Compliance for materials.
- B. Product Data: Manufacturer's data sheet on each type of product furnished.

#### **PART 2: MANUFACTURER**

#### 2.1 MANUFACTURER

Acceptable Manufacturer: Heckmann Building Products 110 Richards Ave. Norwalk, CT 06854-1685 800-621-4140

Email: info@heckmannanchors.com Website: www.heckmannanchors.com

#### 2.2 APPLICATIONS

- A. Provide anchoring systems that comply with the Building Code Requirements for Masonry Structures TMS 402-22.
- B. Stainless Steel AISI [Type 304] [or] [Type 316]
- C. ASTM A240/A240M-15b Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Application.
- D .ASTM A666-15 Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.

# 2.3 MATERIALS

### **NO. 1050 TERMINATION BAR**

# A. Standards

1050-T1-SS: 1/8" x 1" wide x 8ft Stainless - no lip 1050-T2-P 1/8" x 1" wide x 8ft - plastic - with lip 1050-T1-A 14 gauge x 1" x 8ft Aluminum - no lip 1050-T2-A 14 gauge x 1" x 8ft Aluminum - with lip 1050-T2-SS 26 gauge x 1-1/2" wide x 8ft - with lip

# B. Specials

[thickness] x [width] x [length] x [hole diameter] x [hole spacing oc] x hole to start [inches] from end.

C. Materials: [Type 304 Stainless Steel]

# **PART 3: EXECUTION**

A. Install as specified in applicable Masonry/Sheet Metal Flashing section(s).